# Product data sheet Characteristics

## SUVTP15KF2B4S

APC Smart-UPS VT 15kVA 208V w/2 Batt Mod Exp to 4, Start-Up 5X8, Int Maint Bypass, Parallel Capable



#### Commercial status

Discontinued on: 14 January 2021

To be end-of-service on: 31 December 2030

Lead time	Usually Ships within 2 Weeks	
Conoral		
General		
Provided equipment	Battery modules ship installed CD with software	
	Network management card	
	Power modules ship installed	
	Smart UPS signalling RS-232 cable	
	User manual	
	Bolt down brackets	
	Installation guide	
	Start up included	
Performance multiplier	0	
Number of tare power	230 W	
Number of power module free slots	0	
Number of power module filled slots	0	
Redundant	Yes	
Size UPS version	Internetworking	
	Server	
	Telecom	
UPS size	L	
Value multiplier	0	
Dhysical		
Physical		
Colour	Black	
Depth	81.3 cm	
Height	149.9 cm	

Net weight

Mounting location

Mounting mode

Mounting preference

Two post mountable

Front

415 kg

No preference

Not rack-mountable

USB compatible	No
Width	52.3 cm

#### Input

Network frequency	4070 Hz
Number of input connectors	1 hard wire 5-wire (3P + N + E)
Input voltage limits	165240 V
Inputvolt_other	220 V
Maximum input current	40 A
Switching current capacity	60 A
Input voltage	208 V 3 phases
Cos phi	0.98

#### Output

Output	
Rated power in W	12000 W
Maximum configurable power in W	12000 W
Harmonic distortion	Less than 5 % at full load
Output frequency	5763 Hz for 60 Hz nominal sync to mains 60 Hz +/- 0.1 % for 60 Hz nominal unsynchronised
Outputvolt_other	220 V
Crest factor	Unlimited
UPS type	Double conversion online
Wave type	Sine wave
Connections - terminals	1 screw terminals
Output connector type	Hard wire 5-wire (3P + N + E) 1
Bypass type	Built-in maintenance bypass Built-in static bypass
Curve equation	Efficiency
Curve fixed loss	0.018
Curve load maximum	100 %
Curve load minimum	2 %
Curve proportional loss	0.0253
Curve square loss	0.0321
Curve X-axis maximum	100 %
Curve test cond ID	Curve fit to measured efficiency data. All measurements taken in normal operating mode, at typical environmental conditions, with nominal electrical input and balanced PF = 0.8 output.
Curve X-axis minimum	0 %
Curve X-axis title	Load
Curve X-axis units	Percentage
Curve Y-axis maximum	100 %
Curve Y-axis minimum	50 %
Curve Y-axis title	Efficiency
Curve Y-axis units	Percentage
Graph display	0
Maximum output current	46 A
Output voltage	120 V 208 V 208 V 3 phases
Maximum configurable power in VA	15000 VA
Rated power in VA	15000 VA

#### Conformance

Product certifications	CUL listed UL 1778

Standards	ISO 14001 ISO 9001

#### Environmental

Ambient air temperature for operation	040 °C
Relative humidity	095 %
Operating altitude	03333 ft
Ambient air temperature for storage	-5040 °C
Storage altitude	0.0015240.00 m
Acoustic level	54 dBA
Heat dissipation	3276 Btu/h
Show note OP temperature	No
NEMA degree of protection	NEMA 1

#### Batteries & Runtime

Datteries & Nurtuine	
Battery type	VRLA
Number of battery filled slots	2
Number of battery free slots	2
Battery recharge time	5 h
Number of battery replacement quantity	2
Additional information	Configurable for 208 and 220V - 3 Phase
Liquid value	0
Battery voltage	+/- 192 V (split battery referenced to neutral)
Discharge battery voltage	+/- 154 V
Battery curve	В
Battery charger power	1015 W rated
Battery power in VAH	5084 VAh runtime
Battery life	35 year(s)
Battery option	SYBT4 1 7321 VAh SYBT4 2 9704 VAh SUVTBXR6B6S 1 19396 VAh SUVTBXR6B6S 2 34233 VAh SUVTBXR6B6S 3 49194 VAh SUVTBXR6B6S 4 64347 VAh
Extended runtime	1

## Communications & Management

Free slots	0
Preinstalled device	Network management card 2 with environmental monitoring
Control panel	Multifunction LCD status and control console
Alarm	Audible and visible alarms : configurable delays
Emergency power off	Yes

## Packing Units

Package 1 Weight	445.91 kg
Package 1 Height	164.3 cm
Package 1 width	65 cm
Package 1 Length	106.2 cm
Number of Units in Package 3	1

## Offer Sustainability

EU RoHS Directive	Compliant
	EU RoHS Declaration

3

#### Contractual warranty

Warranty

1 year repair or replace, Start-Up Service